Approval Number 240155011

Test Report: 122300901-000100020003, J-00391113 & J-00398330



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

Page 1of 8

22nd January 2024

Temac A.S. Nymburská 53, 289 13 Zverínek, Czech Republic

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS) <u>MATERIAL APPROVAL</u>

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE 5075

'Temafast Economy'. Green coloured, compressed synthetic fibre sheet material manufactured by calendaring. For use with water up to 23°C. This material incorporates a natural ingredient. Please note that water companies will evaluate the evidence provided and may ask for more information and they reserve the right to refuse installation. For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 240155011 APPROVAL HOLDER: TEMAC A.S.

The Scheme reserves the right to review approval.

Approval 240155011 is valid between January 2024 and January 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes

WRAS Approvals Manager