

Approval Number 240355031
Test Report: PB2024000681



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

3rd April 2024

Temac A.S.
Nymburská 53,
289 13 Zverínek,
Czech Republic

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

'Temasil NG'. Blue coloured, compressed fibre gasket material, manufactured by calendaring.
For use with water 85°C.

APPROVAL NUMBER: 240355031
APPROVAL HOLDER: TEMAC A.S.

The Scheme reserves the right to review approval.
Approval 240355031 is valid between March 2024 and March 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager